



UPF PAGE/PROCEDURE CHANGE NOTICE (PRCN)

PRCN Number:	PRCN-UPF-CP-214-R10-02	Effective Date:	08/08/23
NOTE: PRCN Effective Date cannot precede effective date of associated document.			
<input checked="" type="checkbox"/> Intent Change		<input type="checkbox"/> Non-Intent Change	
Associated Document Number:	UPF-CP-214	Rev:	10
Associated Document Title:	Barricades and Signs		
Justification for Change:	Clarification regarding Exclusion Zones		
Identify the scope of the change, including mark-up (i.e., strike-through for deletions, colored text for additions) of any new, removed, or changed content.			
Add sub-section 3.2.2, <i>Exclusion Zones</i> and renumber subsequent sections:			
<p>Exclusion zones can be for safety, health, or environmental reasons. They most commonly involve locations posing immediate danger to life and health, a significant need for environmental protection, or investigation of a significant incident.</p> <p>Exclusion zone demarcation must be distinguished from other barricading systems used on the project by color, tagging, or signs. Barricade tags or signage must be attached to outward-facing sides of the barricade at intervals no greater than 25 feet apart. The exclusion zone barricade must only remain in place for the duration that it takes to eliminate the hazard or risk, or as required by regulation or permit.</p> <p>Safety exclusion zones primarily are erected in situations where there is imminent risk of falling object or when there is a discovery of a hazardous condition (e.g. unstable ground conditions). In such cases, tags or signs must state: "Safety Exclusion Zone, Entry Prohibited" or equivalent.</p> <p>No personnel, including the barricade owner, are permitted to enter an Exclusion Zone unless authorized by the ES&H Manager, or designee, under controlled conditions and following a risk assessment.</p>			
Change title of Section 3.2.3			
FROM:			
3.2.3 Elevated Work/ Overhead Hazards			
When a barricade is erected to protect personnel from overhead hazards (e.g., dropped objects), a general rule for barricade erection boundaries is one foot horizontal for every two feet vertical.			
If this distance is not feasible because of site conditions or restrictions, alternative measures shall be implemented and documented on the Safety Task Analysis and Risk Reduction Talk (STARRT) Card in conjunction with the barricade (e.g., Overhead Safety Watch, safety netting/physical barrier). The Discipline Superintendent must approve the alternative measures on the STARRT card prior to implementation. Authorized personnel working within the established barricade shall remain clear of line of fire hazards created from elevated work activities (e.g., hoisting/rigging, material handling, dropped objects). Refer to Appendix C, Elevated Work Sharing Barricading, for process details for elevated work shared barricading between two work groups.			
TO:			
3.2.4 Elevated Work/Dropped Object Prevention – Barricading Zones:			
The potential for dropped objects, and need to restrict or prevent access, must be determined through risk assessment for the work task or work area. Barricades with hazard and ownership signage must be erected around the drop zone and maintained.			
The following zones must be applied:			
<ul style="list-style-type: none"> • Restricted Access Zone – An area within which a dropped object potential has been recognized and entrants are limited to the personnel needed to perform work. Physical barricades and signage must identify the covered area and the specific risk of the zone (e.g., Danger – Dropped Objects, Restricted Access Zone, Authorized Personnel Only). An example of a restricted access zone may be scaffold erection or dismantlement where ground personnel have a need to access the area inside the restricted zone for management of scaffold materials. • Exclusion Zone – An area within which a dropped object potential has been recognized and personnel are not permitted to enter while the hazard is present or active. These zones are identified as no-entry zones, controlled to prevent unauthorized access. Exclusion zones must be distinguished from other barricading systems, including Restricted Access Zones, by color, tagging, or signs. Tags or signs must state: "Safety Exclusion Zone, Danger Dropped Objects, Entry Prohibited" or equivalent. An example of an exclusion zone may be structural steel erection where no ground personnel are required to be present on a lower level beneath overhead work. <ul style="list-style-type: none"> o No personnel (including the barricade owner) are permitted to enter an exclusion zone while the hazard is present or active. o If the barricade owner needs to enter their exclusion zone, at least one side of the barricade must be lowered to the working surface prior to entering. o Emergency entry into exclusion zones can only be gained by contacting the barricade owner or the responsible supervisor, so the hazard within the exclusion zone can be removed or controlled before entry. 			
As a guide, the minimum radius for restricted access and exclusion zones at ground or lower level, where a straight fall exists, should be 2:1 (e.g., for every 2 feet (0.6 m) in vertical distance, the barricade is brought out 1 foot (0.3 m) in horizontal distance). Where a 2:1 ratio is impractical, the task must be assessed to determine the appropriate area of the drop zone and other mitigation methods. Where there are intervening structures, the risk of objects striking those structures must be assessed and drop zones extended to cover the lower levels affected.			



UPF PAGE/PROCEDURE CHANGE NOTICE (PRCN)

Field supervision and employees must communicate to coworkers and affected personnel the overhead hazards associated with their work tasks. Employees working below an overhead crew must inform that crew of their presence. Such hazards must be discussed and included in the Field Level Hazard Assessment (FLHA) and Dropped Object Prevention Checklist for both crews (refer to UPF-CP-203, *Dropped Object Prevention*) in accordance with Y17-95-64-823, *UPF Field Level Hazard Assessment/Job Hazard Analysis Program (FLHA/JHA) Process*.

Shared barricading for elevated work is permitted only for a few isolated instances. Refer to **Appendix C, Elevated Work Sharing Barricading**, for process details for elevated work shared barricading between two work groups.

Throughout the document change

From: ~~STARRT~~ To: FLHA

Update Section 5.1, Source References:

FROM: Y17-95-64-823, *UPF Safety Task Analysis and Risk Reduction Talk/Job Hazard Analysis Program (STARRT/JHA) Process*

Add to Section 5.2, Interfacing References:

UPF-CP-203, *Dropped Object Prevention*


Y17-95-64-823, *UPF Field Level Hazard Assessment/Job Hazard Analysis Program (FLHA/JHA) Process*

Add to Acronyms:

FLHA Field Level Hazard Assessment


Remove from Acronyms:

~~STARRT—Safety Task Analysis and Risk Reduction Talk~~

Preparer			
UPF ES&H Procedure Writer/Issues Management & IH Lead	Anton R. Panev		08/07/23
		Printed Name/Signature	Date
Approval			
UPF ES&H Manager, BNI	Kieran S. Kelly		07/31/23
		Printed Name/Signature	Date
UPF Startup Manager	Jeremy D. Wilkins		08/08/23
		Printed Name/Signature	Date
UPF Site Manager	Gary J. Cough		07/31/23
		Printed Name/Signature	Date

UPF PAGE/PROCEDURE CHANGE NOTICE (PRCN)

PRCN Number:	PRCN-UPF-CP-214-R10-01	PRCN Rev:	0	Effective Date:	10/26/22
NOTE: PRCN Effective Date cannot precede effective date of associated document.					
<input checked="" type="checkbox"/> PRCN Eligible Intent Change <input type="checkbox"/> Non-Intent Change					
Associated Document Number:	UPF-CP-214	Rev:	10		
Associated Document Title: Barricades and Signs					
<p>Identify the scope of the change, including any new, removed, or changed content. Notate any references, such as Condition Reports, that are driving the change</p> <p>Change Section 3.3.2. Excavation Barricade Requirements, to align with new revision of Y17-95-64-822, <i>UPF Site Excavation and Backfill</i></p> <p>From: All excavations shall have a barricade around the entire perimeter with designated access points.</p> <p>Excavation barricades shall include appropriate signs and tags.</p> <p>Install soft barricades at least 6 feet from open edges of excavations. Use standard guardrail systems or equivalent hard barricade when between 2 and 6 feet from the edge of the excavation.</p> <p>Trenching activities (with straight/sheer cut walls) that present a fall hazard greater than 6 feet shall be protected with appropriate guardrail systems. Addressed in Y17-95-64-822, <i>UPF Site Excavations and Backfill</i>. Reference Section 3.3, <i>Safety Precautions and Requirements</i>, last two bullets.</p> <p>To: All excavations shall have a barricade around the entire perimeter with designated access points until after completion of CFN-1299A, <i>Excavation Release Approval</i>, per Y17-95-64-822, <i>UPF Site Excavations and Backfill</i>, which approves their removal based on the area no longer presenting excavation hazards.</p> <p>Excavation barricades shall include appropriate signs and tags.</p> <p>Install soft barricades at least 6 feet from open edges of excavations. Use standard guardrail systems or equivalent hard barricade when between 2 and 6 feet from the edge of the excavation.</p> <p>Trenching activities (with straight/sheer cut walls) that present a fall hazard greater than 6 feet shall be protected with appropriate guardrail systems; this is addressed in Y17-95-64-822, Section 3.3, last two bullets.</p> <p>Move Y17-95-64-822 from <i>Source References</i>, Section 5.1 to <i>Interfacing References</i>, Section 5.2</p>					

Preparer			
UPF Issues Management:	Mark W. Murdock	 Printed Name/Signature	10/19/22 Date
Approval			
UPF ES&H Manager, BNI:	Kieran S. Kelly	 Printed Name/Signature	10/26/22 Date
UPF Startup Manager:	Jeremy D. Wilkins	 Printed Name/Signature	10/25/22 Date
UPF Site Manager:	Gary J. Cough	 Printed Name/Signature	10/26/22 Date

Barricades and Signs



Preparer: Mark W. Murdock 09/02/22
 Mark W. Murdock Date
 UPF Issues Management

Approval: Kieran S. Kelly 09/02/22
 Kieran S. Kelly Date
 UPF ES&H Manager, BNI

Jeremy D. Wilkins 09/09/22
 Jeremy D. Wilkins Date
 UPF Startup Manager

Robert S. Solberg 09/06/22
 Robert S. Solberg Date
 UPF Site Manager

~~10/10/22~~ 09/30/22
 Effective Date Initials: MWM
 Date: 09/15/22

Pen & Ink for Minor Correction (Non-Intent) in accordance with Y15-95-800
 Page Numbers Affected: Page 1
 Reason for Change:
Effective date changed from 10/10/22 to 09/30/22 due to schedule constraints not being considered when the 30 day ready period was specified.
 O&AS Document Services will ensure the Pen & Ink change is documented as a Pending Update and will be included in the next revision, if appropriate.
 Signatures below confirm the changes made are deemed Non-Intent (Minor Changes) only.

Mark W. Murdock Mark W. Murdock 09/15/22
 Requestor – Printed Name/Signature Date

Kieran S. Kelly Kieran S. Kelly 09/15/22
 Approver – Printed Name/Signature Date
 (RM/FDC for Document)

RC-UPF DMC
 09/12/22 10:04

*Barricades and Signs***REVISION LOG**

Revision 10	<input checked="" type="checkbox"/> Intent <input type="checkbox"/> Non-Intent
<ul style="list-style-type: none"> • These changes are in response to Condition Report 25774-000-GCA-GAM-02998-15, <i>Revise procedure Y17-95-64-822 and UPF-CP-214 to clarify barricading requirements around active Excavations</i> <ul style="list-style-type: none"> ◦ Section 3.1, <i>General Requirements</i>: Added bullet to address use of a door as a barricade ◦ Section 3.2, <i>Soft (Temporary) Barricades</i>: Changed barricade tape height to a range; added wording to open barricade access when no hazard exists or no work is ongoing ◦ Changed “Discipline Superintendent” to Responsible Superintendent” throughout ◦ Section 3.3.2, <i>Excavation Barricade Requirements</i>: Clarified excavation barricade construction methods, additional safety requirements for deeper excavations, and labeling/tagging requirements ◦ Section 3.4, <i>Signs and Tags</i>: Emphasized excavation signage and tagging requirements; removal of signage when hazard no longer present and damaged sign replacement • No forms have been edited as part of this revision • An evaluation determination has been performed confirming that this Procedure does implement requirements tracked in the Programmatic Requirements Management System (PRMS). This document will be added to the PRMS in the future, which is tracked in CR 25774-000-GCA-GAM-03372 • Other changes include: <ul style="list-style-type: none"> ◦ Updated references ◦ Updated acronyms ◦ Editorial changes 	
Revision 9	<input checked="" type="checkbox"/> Intent <input type="checkbox"/> Non-Intent
<ul style="list-style-type: none"> • This revision was preparer under Y15-95-235, <i>UPF Command Media</i>, Revision 11 • The following changes are in response to Condition Report 25774-000-GCA-GAM-02999, Y-12 <i>APMO-F-2: Contradictory Procedural Requirements and Need to Clarify Revision 8 of UPF-CP-214, Barricades and Signs (ASRP-C&ESH-2.11.2021-906017)</i>: <ul style="list-style-type: none"> ◦ Clarified the roles and responsibilities for Supervisors and Discipline Superintendents throughout the document, specifically in Appendix C, <i>Elevated Work Sharing Barricading</i> ◦ Clarified the process for shared barricades and use of Overhead Safety Watch (changed from Spotter) • An evaluation determination has been performed confirming that this Procedure does not implement requirements as tracked in the Programmatic Requirements Management System (PRMS) • Added Section 2.5, <i>UPF Responsible Supervisor</i>; subsequent sections renumbered • Section 2.6, <i>UPF Subcontractor Technical Representative</i> • Added section 3.2.6, <i>Restricted Area Startup Controlled Area</i>, that includes barricading for Startup activities • Other changes include: <ul style="list-style-type: none"> ◦ Added roles for Project Startup Manager and Test Lead ◦ Clarified toeboard requirements ◦ Added to table in Appendix B, <i>Common Application of Barricades and Signs</i> 	
Previous revisions on record	

CONTENTS

1.0 INTRODUCTION.....	4
1.1 Purpose.....	4
1.2 Scope	4
2.0 RESPONSIBILITIES.....	4
2.1 UPF Site Manager/Project Startup Manager	4
2.2 UPF Environmental, Safety and Health Manager, Bechtel National, Inc.....	4
2.3 UPF Environmental, Safety, and Health Representative, BNI.....	4
2.4 UPF Discipline Superintendent/Test Lead.....	4
2.5 UPF Responsible Supervisor.....	5
2.6 UPF Subcontractor Technical Representative	5
2.7 UPF Personnel.....	5
3.0 REQUIREMENTS	5
3.1 General Requirements.....	5
3.2 Soft (Temporary) Barricades.....	6
3.3 Protective (Hard) Barricades.....	9
3.4 Signs and Tags.....	10
4.0 RECORDS	11
5.0 REFERENCES.....	11
5.1 Source References.....	11
5.2 Interfacing References	12
6.0 SUPPLEMENTAL INFORMATION	12
APPENDIX A Acronyms and Definitions	13
APPENDIX B Common Application of Barricades and Signs.....	14
APPENDIX C Elevated Work Sharing Barricading.....	16

1.0 INTRODUCTION

1.1 Purpose

This Procedure describes the barricade and signage requirements for controlling (informing and/or restricting) entry into areas that contain safety hazards, abnormal conditions, or where work activities require restricted access.

1.2 Scope

This Procedure applies to all personnel (including subcontractors) who perform work at the Uranium Processing Facility (UPF) Project.

2.0 RESPONSIBILITIES

2.1 UPF Site Manager/Project Startup Manager

The Site Manager is responsible for ensuring the implementation of this Procedure by the UPF site personnel. The Project Startup Manager has the overall responsibility for the implementation of this Procedure as it pertains to systems that have been turned over to Startup.

2.2 UPF Environmental, Safety and Health Manager, Bechtel National, Inc.

The Environmental, Safety, and Health (ES&H) Manager, Bechtel National, Inc. (BNI) is responsible for interpreting this Procedure (intent and application) and the associated requirements.

2.3 UPF Environmental, Safety, and Health Representative, BNI

The ES&H Representative, BNI is responsible for:

- Reviewing compliance with this Procedure through periodic field inspections
- Assisting site personnel to determine the appropriate protective measures for recognized hazards

2.4 UPF Discipline Superintendent/Test Lead

The Discipline Superintendent is responsible for:

- Understanding this Procedure and their individual responsibilities regarding implementation of this Procedure
- Pre-planning work activities to identify the appropriate barricade to use
- Communicating the identified hazards and controls to supervisors and/or work crews
- Ensuring the identified control measures are in place and maintained until the completion of the job task

<i>Barricades and Signs</i>

2.5 UPF Responsible Supervisor

The Responsible Supervisor is responsible for:

- Understanding this Procedure and their individual responsibilities regarding implementation of this Procedure
- Pre-planning work activities to identify the appropriate barricade to use
- Communicating the identified hazards and controls to work crews and those in surrounding areas impacted by their work requiring a barricade
- Ensuring the barricades and signs are properly erected and maintained and they are removed when the hazard has been mitigated or the work activity is complete

2.6 UPF Subcontractor Technical Representative

The Subcontractor Technical Representative is responsible for:

- Providing oversight of Subcontractor work activities as it applies to this Procedure
- Facilitating communication and coordination of work activities between subcontractors and direct-hire work scope as it applies to this Procedure

2.7 UPF Personnel

Site personnel are responsible for:

- Understanding and complying with the requirements of this Procedure
- Pausing/stopping work when they are unsure of the requirements for a work task, or they witness an unsafe condition or behavior

3.0 REQUIREMENTS

3.1 General Requirements

The general requirements for barricades and signs are as follows:

- Personnel initiating the work, or creating the hazard, are responsible for erecting the barricade and maintaining it throughout the scope of work; the barricade must be established prior to the start of the work task
- Barricades must be erected to fully encompass the hazard or work activity
- Signs (or tags) shall be used in conjunction with barricades to provide specific warnings and/or other essential information about the hazard(s) that exist within the barricaded area
- Personnel are not allowed to step over or duck under barricades; only designated access points will be utilized to enter a barricade
- Dismantle soft barricades at the end of the shift, or when the hazard has been abated, or when the work requiring the barricade has been completed
- Where hazards are expected to exist for more than 24 hours (e.g., excavations), a protective (hard) barricade should be erected
- Soft barricades are prohibited as edge protection for fall protection hazards
- Barricades should not block emergency equipment (e.g., fire extinguishers, emergency eyewash stations) or emergency egress routes; where this is

<i>Barricades and Signs</i>

infeasible, provisions must be made by the Responsible Supervisor and with approvals as necessary by the Responsible Superintendent

- Where a door is determined by the Discipline Superintendent to be the most effective barricade, signage or other controls may be utilized to identify the door as an effective barricade provided both of the following are true:
 - The configuration of controls shall communicate the hazard being controlled
 - The door's functionality shall remain fully intact to enable occupants to complete an egress activity to the public way from the contained space
- For common application of barricades and signs and their appropriate warnings, see **Appendix B, *Common Application of Barricades and Signs***

3.2 Soft (Temporary) Barricades

The general requirements for soft (temporary) barricades are as follows:

- Use only reinforced barricade tape, plastic chain, or rope for erecting soft barricades
- Utilize portable stanchions/posts, columns, or other fixed objects to secure/support soft barricades
- Where personnel require access into a barricade, provide removable access point(s); place appropriate barricade tags and/or signs at those access points
- Install barricade tape approximately 36 to 48 inches high so it can be easily recognized

NOTE: *Do not secure barricades to sensitive permanent plant or emergency equipment (e.g., gauges, indicators, fire extinguishers).*

- If there is no current or active hazard and hazardous work is not actively in progress (e.g., during lunch break), remove the barricade tape from the entrance to a barricaded work area (e.g., the signed Access Point)
- Do not leave an area barricaded when there is no active hazard or when work has been completed
- Establishing or maintaining barricades to exclude entry into an area for convenience to the barricade owner is not allowed
- Refer to OT-SH-801768-A129, *Guidance for Barricade Erection*

3.2.1 Caution Barricades

Use caution barricades to ensure personnel are aware of physical hazards or changing conditions.

Personnel can pass through a caution barricade only after hazards are recognized and it is determined to be safe to proceed through the area. Personnel should verify conditions and contact the responsible person listed on the sign/tag if they are unsure of safe passage.

3.2.2 Exclusion Zones

Exclusion zones can be for safety, health, or environmental reasons. They most commonly involve locations posing immediate danger to life and health, a significant need for environmental protection, or investigation of a significant incident.

<i>Barricades and Signs</i>

Exclusion zone demarcation must be distinguished from other barricading systems used on the project by color, tagging, or signs. Barricade tags or signage must be attached to outward-facing sides of the barricade at intervals no greater than 25 feet apart. The exclusion zone barricade must only remain in place for the duration that it takes to eliminate the hazard or risk, or as required by regulation or permit.

Safety exclusion zones primarily are erected in situations where there is imminent risk of falling object or when there is a discovery of a hazardous condition (e.g. unstable ground conditions). In such cases, tags or signs must state: "Safety Exclusion Zone, Entry Prohibited" or equivalent.

No personnel, including the barricade owner, are permitted to enter an Exclusion Zone unless authorized by the ES&H Manager under controlled conditions and following a risk assessment.

3.2.3 Elevated Work/Dropped Object Prevention – Barricade Zones

The potential for dropped objects, and need to restrict or prevent access, must be determined through risk assessment for the work task or work area. Barricades with hazard and ownership signage must be erected around the drop zone and maintained.

The following zones must be applied:

- Restricted Access Zone – An area within which a dropped object potential has been recognized and entrants are limited to the personnel needed to perform work. Physical barricades and signage must identify the covered area and the specific risk of the zone (e.g., Danger – Dropped Objects, Restricted Access Zone, Authorized Personnel Only). An example of a restricted access zone may be scaffold erection or dismantlement where ground personnel have a need to access the area inside the restricted zone for management of scaffold materials.
- Exclusion Zone – An area within which a dropped object potential has been recognized and personnel are not permitted to enter while the hazard is present or active. These zones are identified as no-entry zones, controlled to prevent unauthorized access. Exclusion zones must be distinguished from other barricading systems, including Restricted Access Zones, by color, tagging, or signs. Tags or signs must state: "Safety Exclusion Zone, Danger Dropped Objects, Entry Prohibited" or equivalent. An example of an exclusion zone may be structural steel erection where no ground personnel are required to be present on a lower level beneath overhead work.
 - No personnel (including the barricade owner) are permitted to enter an exclusion zone while the hazard is present or active.
 - If the barricade owner needs to enter their exclusion zone, at least one side of the barricade must be lowered to the working surface prior to entering.
 - Emergency entry into exclusion zones can only be gained by contacting the barricade owner or the responsible supervisor, so the hazard within the exclusion zone can be removed or controlled before entry.

As a guide, the minimum radius for restricted access and exclusion zones at ground or lower level, where a straight fall exists, should be 2:1 (e.g., for every 2 feet (0.6 m) in vertical distance, the barricade is brought out 1 foot (0.3 m) in horizontal distance). Where a 2:1 ratio is impractical, the task must be assessed to determine the

PRCN 02

PRCN 02

<i>Barricades and Signs</i>

appropriate area of the drop zone and other mitigation methods. Where there are intervening structures, the risk of objects striking those structures must be assessed and drop zones extended to cover the lower levels affected.

Field supervision and employees must communicate to coworkers and affected personnel the overhead hazards associated with their work tasks. Employees working below an overhead crew must inform that crew of their presence. Such hazards must be discussed and included in the FLHA and Dropped Object Prevention Checklist for both crews (refer to UPF-CP-203, *Dropped Object Prevention*) in accordance with Y17-95-64-823, *UPF Field Level Hazard Assessment/Job Hazard Analysis Program (FLHA/JHA) Process*.

Shared barricading for elevated work is permitted only for a few isolated instances. Refer to **Appendix C, *Elevated Work Sharing Barricading***, for process details for elevated work shared barricading between two work groups.

3.2.4 **Elevated Work/Overhead Hazards**

When a barricade is erected to protect personnel from overhead hazards (e.g., dropped objects), a general rule for barricade erection boundaries is one foot horizontal for every two feet vertical.

If this distance is not feasible because of site conditions or restrictions, alternative measures shall be implemented and documented on the Field Level Hazard Assessment (FLHA) Card in conjunction with the barricade (e.g., Overhead Safety Watch, safety netting/physical barrier). The Discipline Superintendent must approve the alternative measures on the FLHA card prior to implementation.

Authorized personnel working within the established barricade shall remain clear of line-of-fire hazards created from elevated work activities (e.g., hoisting/rigging, material handling, dropped objects).

Refer to **Appendix C, *Elevated Work Sharing Barricading***, for process details for elevated work shared barricading between two work groups.

3.2.5 **Radiation Barricades**

A radiation barricade will consist of yellow and magenta rope (or equivalent) combined with "Radiation Area" and/or "High Radiation Area" signs.

Personnel shall not cross/enter or otherwise modify radiation barricades. Only personnel who are licensed and trained are authorized to enter the barricaded area.

For radiography (non-destructive examination) work, radiation barricades shall incorporate flashing lights or other visual indicators.

3.2.6 **Restricted Area**

A Restricted Area barricade will consist of white rope, chain, or equivalent combined with "Restricted Area" signs.

Established for the general exclusion of personnel for the protection of property/work process (e.g., wet paint).

Personnel must contact the responsible person listed on the sign/tag and verify conditions before entering.

PRCN 02

PRCN 02

<i>Barricades and Signs</i>

3.2.7 Restricted Area Startup Controlled

A Startup Controlled Area barricade will consist of green rope, chain, or equivalent combined with “Restricted Area Startup Controlled” signs.

Established by Startup Test Engineer (STE) for the general exclusion of non-essential personnel for the protection of Startup Controlled systems or components Startup operation/testing process.

Personnel must contact the responsible person listed on the sign/tag and verify conditions before being allowed to enter.

3.3 Protective (Hard) Barricades

3.3.1 Guardrail Requirements

Guardrail systems can be constructed using wood, metal, or a combination of both.

Top rails shall be 42 inches plus-or-minus three inches (i.e., 39 to 45 inches) above the walking/working level. When conditions warrant, the height of the top edge may exceed the 45-inch height, provided the guardrail system meets all other criteria of this section.

Mid-rails, screens, mesh, intermediate vertical members, or equivalent intermediate structural members shall be installed between the top rail of the guardrail system and the walking/working surface according to the following guidelines:

- Mid-rails, when used, shall be installed at a height midway between the top rail and the walking/working surface (approximately 21 inches)
- Screens and mesh, when used, shall extend from the top rail to the walking/working level and along the entire opening between the top rail supports
- Intermediate members (such as balusters), when used between posts, shall not be more than 19 inches apart

Guardrail systems shall be capable of withstanding, without failure, a force of at least 200 pounds applied within two inches of the top edge, in any outward or downward direction, at any point along the top edge.

A toeboard, or equivalent mesh/debris netting, must be installed on guardrails for all elevated work surfaces where dropped objects can present a hazard to personnel working below.

Toeboards shall be a minimum of 3½ inches in vertical height from their top edge to the level of the walking/working surface. They shall have no more than ¼-inch clearance above the walking/working surface.

Wood Guardrail Requirements

Wooden top rails, mid-rails, and posts must be constructed from nominal 2-inch by 4-inch lumber, at minimum.

Wooden guardrail posts cannot be spaced greater than 8 feet, unless otherwise designed/engineered.

Barricades and Signs**Metal Guardrail Requirements**

Metal top rails, mid-rails, and posts must be constructed from 1½-inch nominal size or larger material.

Cable/Wire Rope Guardrail Requirements

Cable top rails and mid-rails shall be at least ½-inch nominal diameter or thickness to prevent cuts and lacerations.

Wire rope top rails will be flagged with high-visibility material at intervals of no more than 6 feet. Debris netting may be used in place of this flagging requirement.

3.3.2 Excavation Barricade Requirements

All excavations shall have a barricade around the entire perimeter with designated access points.

Excavation barricades shall include appropriate signs and tags.

Install soft excavation barricades at least 6 feet from open edges of excavations. Use standard guardrail systems or equivalent hard barricade when between 2 and 6 feet from the edge of the excavation.

Trenching activities (with straight/sheer cut walls) that present a fall hazard greater than 6 feet shall be protected with appropriate guardrail systems. Addressed in Y17-95-64-822, *UPF Site Excavation and Backfill*. Reference Section 3.3, *Safety Precautions and Requirements*, last two bullets.

3.3.3 Roadway Barricades

Protective barriers across or next to an active roadway will be substantial concrete vehicle barriers or other manufactured Jersey-style barriers (e.g., sand/water filled), and will include roadway signs (or equivalent) to alert vehicle traffic when personnel are working in or adjacent to the roadways.

Visual indicators (e.g., flashing amber lights or reflective strips) are required on barriers left after dark to alert vehicle traffic that a barrier is there.

3.4 Signs and Tags

Excavation barricades shall include appropriate signs and tags.

3.4.1 General Requirements for Signs

Signs should be printed on material suitable to the environment (e.g., plastic or metal), or protected in a way to prevent damage and fading.

Signs shall be removed when the hazard is no longer present, and replaced when significantly damaged or illegible.

Signs should include a description of the hazard(s) and instructions, as applicable.

See **Appendix B** for additional sign types and warning requirements/instructions.

<i>Barricades and Signs</i>

3.4.2 General Requirements for Tags

Tags should include a description of the hazard(s) and instructions, as applicable. Contact information for the Responsible Supervisor is required on the tag.

4.0 RECORDS

None

5.0 REFERENCES

5.1 Source References

10 CFR 851, *Worker Safety and Health Program*

29 CFR 1926 Subpart G, *Signs, Signals, and Barricades*

29 CFR 1926 Subpart M, *Fall Protection*

ML-CM-801768-A019, *UPF Construction Hazard Tree*

ML-SU-801768-A001, *UPF Startup Hazard Tree*

NS&E CP 2HC-E0S0-00214-000, *Barricades and Signs*

UPF-CP-108, *UPF Event Management and Investigation*

UPF-CP-200, *UPF General Safe Work Practices*

UPF-CP-211, *Fire Prevention and Protection*

UPF-CP-227, *UPF Safety Watches*

UPF-CP-229, *Vehicle Safety Management*

UPF-CP-312, *Hearing Conservation Program*

UPF-CP-318, *Respirator Use and Issuance*

UPF-MANUAL-CM-001, *Uranium Processing Facility Construction Electrical Safety Manual*

UPF-MANUAL-SH-A001, *UPF Elevated Work Manual*

Y17-95-64-801, *UPF Energy Isolation Management (EIM) – Lockout/Tagout (LOTO)*

Y17-95-64-806, *UPF Pressure Testing of Piping, Tubing, and Components*

Y17-95-64-822, *UPF Site Excavation and Backfill*

Y17-95-64-837, *UPF Housekeeping*

Y17-95-64-855, *UPF Structural Steel Erection*

Y17-95-64-871, *UPF Construction Hoisting and Rigging Work Operations*

Y17-95-64-872, *UPF Crane Use and Operation*

Y17-95-64-877, *UPF Hot Work Permit*

Y72-95-003, *Silica Exposure Control Procedure for the Construction of the Uranium Processing Facility Project*

<i>Barricades and Signs</i>

Y73-95-802, *Confined Space Entry Program*

Y73-95-803, *Hexavalent Chromium Procedure*

Y75-100, *Y-12 Site Radiological Control Program*

5.2 Interfacing References

OT-SH-801768-A129, *Guidance for Barricade Erection*

UPF-CP-203, *Dropped Object Prevention*

Y17-95-64-823, *UPF Field Level Hazard Assessment/Job Hazard Analysis Program (FLHA/JHA) Process*

6.0 SUPPLEMENTAL INFORMATION

Appendix A, *Acronyms and Definitions*

Appendix B, *Common Application of Barricades and Signs*

Appendix C, *Elevated Work Sharing Barricading*

APPENDIX A Acronyms and Definitions

Acronyms

BNI	Bechtel National, Inc.
ES&H	Environmental, Safety, and Health
FHLA	Field Level Hazard Assessment
STE	Startup Test Engineer
UPF	Uranium Processing Facility

Definitions:

Barricade	A system designed to warn of a hazard and physically identify the hazard's parameters.
Signs	A posting bearing information, advisory, or a warning of hazards, which is temporarily or permanently affixed or placed at locations where the hazards exist.
Tags	Temporary postings, usually attached to a piece of equipment or part of a structure (e.g., scaffolding), to warn or inform workers of a condition or requirement. Tags are also used in conjunction with barricades to provide specific warnings and/or other essential information about the hazard(s) that exist beyond the barricade.

APPENDIX B

Common Application of Barricades and Signs

(Page 1 of 2)

NOTE: Signs/tags can be used independent of a barricade; however, if a barricade or delineation of an area is required, follow the guidelines below.

WARNING HEADER	DESCRIPTION	BARRICADE/ DELINEATION	APPLICATIONS
	<p>DANGER Shall be used for a condition or process that has the potential to cause a serious or life threatening injury or illness.</p>	<p>RED OR RED/BLACK</p> <ol style="list-style-type: none"> 1) Webbed Barricade Tape 2) Rope 3) Plastic Chain 	Examples include High Voltage, Hexavalent Chromium, Permit Required Confined Space, Abrasive Blasting, Crane Counterweight Swing Radius, Pneumatic Pressure Testing, Overhead Work, and Respiratory Protection Required.
	<p>CAUTION Shall be used only to warn against physical hazards or to caution against changing conditions.</p>	<p>YELLOW OR YELLOW/BLACK</p> <ol style="list-style-type: none"> 1) Webbed Barricade Tape 2) Rope 3) Plastic Chain 	Examples include Noise Conditions, Non-Permit Confined Space, Low Clearance Areas, Open Excavations, and Wet/Slippery Surfaces.
	<p>NOTICE Provides information or safety requirements.</p>		Examples include Personal Protective Equipment free zones, No Dark Lenses Beyond this Point, and Laydown Areas.
	<p>RESTRICTED AREA Used for the general safety of personnel, establishing exclusion areas, or the protection of property/process.</p>	<p>WHITE</p> <ol style="list-style-type: none"> 1) Rope 2) Plastic Chain 	Examples include Wet Paint, Do Not Enter, and Authorized Personnel Only.
	<p>RESTRICTED AREA STARTUP CONTROLLED Established for the general exclusion of personnel for the protection of Startup Controlled systems or components Startup operation/testing process.</p>	<p>GREEN</p> <ol style="list-style-type: none"> 1) Rope 2) Barricade Tape 3) Plastic Chain 	Examples include Areas, Systems, or Components controlled by Startup
	<p>RADIOLOGICAL Used <u>ONLY</u> where radiological hazards are or may be present.</p>	<p>MAGENTA AND YELLOW</p> <ol style="list-style-type: none"> 1) Rope 2) Barricade Tape 	Examples include Radiation Areas and High Radiation Areas typically associated with radiography (non-destructive examination) work.

APPENDIX B

Common Application of Barricades and Signs

(Page 2 of 2)

ADDITIONAL SIGNS/SPECIFICATIONS		
Exit Signs	Red letters, no less than 6 inches high, on a white field, and the principal stroke of the letters shall be at least 3/4 of an inch in width.	
Traffic and Road Signs	Provide information to operators of motor vehicles including, but not limited to, Department of Transportation signage required on public roads. Also including traffic control devices (e.g., signs, signals, markings, and barricades) for protection of workers that must conform to Part 6 of the Manual on Uniform Traffic Control Devices.	Speed Limit, Pedestrian Crossing, Stop, Curve, One Way, Two Way, Work Crew Ahead, Flaggers Ahead, and Do Not Enter.
Fire Signs	Provide information on the location of firefighting equipment.	Fire Extinguisher
Prohibition Signs	Provide information on prohibited actions.	No Smoking and No Parking
Emergency Signs	Typically includes white lettering on a green background with the appropriate symbols. Provide information on the location of emergency equipment.	Eyewash Station, Automated External Defibrillators, and Emergency Rescue Equipment.

APPENDIX C

Elevated Work Sharing Barricading

Before implementing an elevated work shared barricade with another work group, the Responsible Superintendent(s)/Subcontractor Technical Representative(s)/STE will ensure the following requirements are met:

- Affected personnel from both work groups participate on a joint FLHA card to identify the dropped object hazards and the controls that will be employed
- An Overhead Safety Watch (hereinafter referred to as "Watch") is designated and noted on the FLHA card
- The Watch will be positioned outside of the barricaded area and must be in a position to observe the coexisting activities
- The Watch will have no other duties assigned that would interfere with their ability to perform their duties
- Communication between personnel conducting the coexisting work activities will be maintained by the Watch
- Prior to moving or changing work location, personnel will communicate their intentions with the Watch to ensure the coexisting work activities are not impacted
- Multiple Watches may be required to adequately oversee the work activities; communication between multiple Watches and the elevated work groups must be maintained
- If at any point during the elevated work activities, the Watch is unable to maintain observation and/or communication with the work groups, activities shall be paused; the Watch will be repositioned and/or the coexisting work activities reevaluated

NOTE: *A 1-foot, horizontal separation distance for every 2 feet of vertical work location shall be maintained between work groups within the shared barricade. When the 1 to 2 ratio cannot be maintained between the two work activities, the uppermost elevated work will be directed to pause and secure the work until the appropriate distance can be re-established within the confines of the shared barricade.*

DISCLAIMER

This work of authorship and those incorporated herein were prepared by Consolidated Nuclear Security, LLC (CNS) as accounts of work sponsored by an agency of the United States Government under Contract DE-NA-0001942. Neither the United States Government nor any agency thereof, nor CNS, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility to any non-governmental recipient hereof for the accuracy, completeness, use made, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency or contractor thereof, or by CNS. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency or contractor (other than the authors) thereof.

COPYRIGHT NOTICE

This document has been authored by Consolidated Nuclear Security, LLC, under Contract DE-NA-0001942 with the U.S. Department of Energy/National Nuclear Security Administration, or a subcontractor thereof. The United States Government retains and the publisher, by accepting the document for publication, acknowledges that the United States Government retains a nonexclusive, paid-up, irrevocable, world-wide license to publish or reproduce the published form of this document, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, or allow others to do so, for United States Government purposes.